

2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 23 May 2003	4. REQUISITION/PURCHASE REQ. NO. W38XGR-3092-2413	5. PROJECT NO. <i>(If applicable)</i> DACW66-03-B-0011
6. ISSUED BY Department of the Army Memphis District, Corps of Engineers 167 North Main Street, Rm B202 ATTN: CEMVM-CT Memphis, TN 38103-1894		7. ADMINISTERED BY <i>(If other than Item 6)</i> CODE	

8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>	(√)	9A. AMENDMENT OF SOLICITATION NO. DACW66-03-B-0011
	X	9B. DATED <i>(SEE ITEM 11)</i> 05 May 2003
		10A. MODIFICATION OF CONTRACTS/ORDER NO.
		10B. DATED <i>(SEE ITEM 13)</i>
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(√)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*

This solicitation for Austin, Mississippi Seepage Relief Wells, Tunica County, Mississippi scheduled to open 5 Jun 2003 at 2:30 p.m., is amended as follows:

1. Section 00100 - Instructions to Bidders: Contract Clause No. 52.232-15 entitled "Progress Payments Not Included", is deleted in its entirety.

"CONTINUED ON NEXT PAGE"

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>	16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
_____ <i>(Signature of person authorized to sign)</i>		BY _____ <i>(Signature of Contracting Officer)</i>	

SPECIFICATIONS

1. SECTION 01025, Page 01025-4, Paragraph 1.2.1 (2) b. Delete the next to the last sentence and replace with “No separate payment will be made for relief well screen, risers, gravel pack, grout, development, sand backfill, concrete pads, discharge or outlet discharge assembly.”
2. SECTION 02708, Page 02708-1, Paragraph 1.1. In the second sentence following “guard posts;” add “concrete pads;”.
3. SECTION 02708, Page 02708-16, Paragraph 3.1.13. In the third sentence, delete the word “slab” and replace with “pad”.

DRAWINGS

1. DRAWING NO. 2. The label for point #18 on the plan view is labeled incorrectly. The station equation should be changed from $41/52+80=42/0+00$ to $42/50+21=43/0+00$.
2. DRAWING NO. 6. In the Detail of Concrete Pad, it should be indicated that the dimensions shown should be for a **square** 5’x5’ concrete pad.
3. DRAWING NO. 6. The guard posts shown on this drawing should be spaced from the corner of the concrete pads as shown on the Stainless Steel Plate Detail from Drawing No. 7.
4. DRAWING NOS. 6 and 7. In the Relief Well Detail, change “CONCRETE SLAB” to “CONCRETE PAD”.
5. **NOTE: NEW OR REVISED DRAWINGS WILL NOT BE ISSUED DUE TO THIS AMENDMENT. MAKE PEN AND INK CHANGES AS NECESSARY.**